

SECTION E

STANDARD STORMWATER NOTES

Page Left Intentionally Blank

STANDARD STORMWATER NOTES

These notes shall be placed on all plans for construction:

1. All workmanship and materials shall be in accordance with County standards and the most current copy of the State of Washington Standard Specifications for Road, Bridge and Municipal Construction (WSDOT/APWA) and as amended by the County or the State.
2. Temporary erosion/water pollution prevention measures shall be required in accordance with the Pierce County Stormwater Management Manual and the Dept. of Ecology's Construction Stormwater General Permit.

Should the temporary erosion and sedimentation control measures as shown on this drawing not prove adequate to control erosion and sedimentation, the applicant/contractor shall install additional facilities as necessary to protect adjacent properties, sensitive areas, natural water courses, and/or storm drainage systems.

3. Call the underground locate line 1-800-424-5555 a minimum of 48 hours prior to any excavations.
4. The storm drainage system shall be constructed according to approved plans on file with the County. Any significant deviation from the approved plans will require written approval from the County.
5. A copy of the approved Construction Stormwater Pollution Prevention Plan and stormwater plans must be on the job site whenever construction is in progress.
6. All erosion control and stormwater facilities shall be regularly inspected and maintained by the designated Certified Erosion and Sediment Control Lead (CESCL) during construction.
7. It shall be the sole responsibility of the contractor to obtain street use and other related or required permits prior to any construction activity in the Municipality's right-of-way. It shall also be the responsibility of the contractor to obtain all required permits prior to any construction. The contractor shall abide by all requirements for traffic control & safety when working in the road right-of-way.
8. The Contractor shall notify the Project Engineer in the event of discovery of poor soils, standing groundwater, or severe discrepancies from soil log descriptions as noted on the plans.
9. For public systems, the contractor shall call for inspection 48 hours prior to covering any drainage structure.
10. All drainage structures, such as catch basins and manholes, not located within a traveled roadway or sidewalk, shall have solid locking lids. All drainage structures associated with a permanent retention/detention facility shall have solid locking lids.

Page Left Intentionally Blank